

The manufacturer may use the mark:



Valid until October 1, 2017 Revision 1.0 September 26, 2014



ANSI Accredited Program PRODUCT CERTIFICATION #1004

Certificate / Certificat Zertifikat / **合格証**

RAD 1406037 C001

exida hereby confirms that the:

FPGA-Based Safety Controller (FSC) RadICS produced by RPC Radiy 29 Geroyiv Stalingrada Street

Kirovograd, Ukraine

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7 and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type B Element

SIL 3 @ HFT = 0; Route 1_H PFD_{AVG} and Architecture Constraints must be verified for each application

Safety Function:

The FSC will read input signals, perform user-defined application layer logic and write results to the output signals within the stated response time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Chaluka

Certifying Assessor

Page 1 of 2

FPGA-Based Safety Controller (FSC) RadICS

Certificate / Certificat / Zertifikat / 合格証 RAD 1406037 C001 Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type B Element

SIL 3 @ HFT=0; Route 1_H PFD_{AVG} and Architecture Constraints must be verified for each application

Systematic Capability :

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element.

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of average Probability of Failure on Demand (PFD_{AVG}), or Probability of Failure per hour (PFH), considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification: Assessment Report: RAD 14-06-037 R002 V1R0 61508 Assessment - FSC Safety Manual: D11.1 - Radiy FSC Product Safety Manual V1R2



64 N Main St Sellersville, PA 18960